



PLAN REVIEW REQUIREMENTS FOR EXCHANGE CABINET INSTALLATION



The following information is required for a plan review submittal for LP Gas exchange cylinder cabinet installation. Required information **shall only be submitted by a Utah licensed LP Gas installer** and shall include the original drawings or readable copy. **Do not send faxes. Insufficient information, non readable copy, or nonpayment of fees will be cause for rejection of plans.**

1. Name, address, and phone number of concern where the tank is to be located as well as name/s of contact personnel at installation location.
2. Name, address, and phone number of the Utah State licensed and certified installers.
3. Provide a copy of approval from the jurisdiction having authority: **Building, Planning, Zoning, and or Fire Department.**
4. Plan or sketch complying with **NFPA 58 (2008)**:
 - 1) Capacity of cabinet including size and number of cylinders to be stored.
 - 2) Distances from building openings and distances from sources of ignition.(10 feet from all doorways, electrical outlets, ice machines and telephones)
 - 3) Indicate the type of approved vehicle protection to be used.
 - 4) Exchange cabinet to have required signage: No Smoking, Propane, and Flammable Gas.
 - 5) Provide location of fire extinguisher within 50 feet of storage cabinet no less than a minimum 10 lb. BC rating. (18 lb. B.C. if aggregate storage is in excess of 720 lbs.)
 - 6) Required fee of **\$75.00** shall accompany all plans submitted for review.

Make Checks payable to the **Utah State Fire Marshals Office** and submit to:

**UTAH STATE FIRE MARSHAL
5274 SOUTH COLLEGE DR. SUITE # 302
MURRAY, UTAH 84123-2611
(801) 284-6350**

